



Linda S. Adams
Secretary for
Environmental Protection

California Regional Water Quality Control Board

San Diego Region



Arnold Schwarzenegger
Governor

Over 50 Years Serving San Diego, Orange, and Riverside Counties

Recipient of the 2004 Environmental Award for Outstanding Achievement from USEPA

9174 Sky Park Court, Suite 100, San Diego, California 92123-4353
(858) 467-2952 • Fax (858) 571-6972
<http://www.waterboards.ca.gov/sandiego>

September 29, 2010

In reply refer to:
adai: 255735

Mr. Fred Edgecomb
Water Reclamation Manager
Rancho California Water District
P.O. Box 9017
Temecula, CA 92589-9017

Dear Mr. Edgecomb:

SUBJECT: REVIEW OF MONITORING REPORTS FOR SANTA ROSA WATER RECLAMATION FACILITY (WRF)

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the April-July 2010 monthly monitoring reports, the April-June 2010 quarterly monitoring report, and the January-June 2010 semiannual monitoring report submitted by the Rancho California Water District in accordance with Monitoring and Reporting Program No. 94-92.

The San Diego Water Board identified the following violations of Section B (Discharge Specifications) of Order No. 94-92 in the reports submitted:


1. The daily maximum discharge specification for total dissolved solids, established at 825 milligrams per liter (mg/L), was exceeded on May 19 and June 23, 2010 with reported values of 850 mg/L and 900 mg/L, respectively.

Please be aware these violations subject you to possible further enforcement action by the San Diego Water Board, including administrative enforcement orders requiring the you to cease and desist from violations, or to clean up waste and abate existing or threatened conditions of pollution or nuisance; administrative assessment of civil liability in amounts of up to \$5,000 per day per violation;¹ referral to the State Attorney General for injunctive relief; and referral to the District Attorney for criminal prosecution.

The next monitoring report to be submitted is the August 2010 monthly monitoring report due by September 30, 2010.

¹ Under authority of California Water Code section 13350.

California Environmental Protection Agency



010N\0W\0


Mr. Fred Edgecomb

- 2 -

September 29, 2010

In the subject line of any response, please include the requested "In reply refer to:" information located in the heading of this letter. For questions pertaining to the subject matter, please contact Amanda Dai at (858) 627-3977 or via email at adai@waterboards.ca.gov.


Sincerely,



Robert Morris, P.E.
Senior Water Resource Control Engineer
Cleanup and Land Discharge Branch

Regulatory Measure: 376052
CIWQS Violation: 881746, 881747

California Environmental Protection Agency



CHON\GW\G